

ADDENDUM A-01

Project:	Request for Quotation – Raw Water Reservoirs Fencing
Addendum:	A-01
Date:	September 21, 2022
Location:	Drumheller, Alberta

To All Bidders:

1. General

- 1.1. This addendum shall be read in conjunction with the Specifications prepared for the Request for Quotation – Raw Water Reservoirs Fencing.
- 1.2. Where inconsistent with the above, this addendum shall govern. This addendum forms an integral part of the Contract Documents and shall be included therein.
- 1.3. No consideration shall be allowed for increases (extras) to the CONTRACT PRICE due to failure of the Contractor or Subcontractor not being familiar with this addendum.
- 1.4. The Bidder shall insert in the Tender Form the number(s) of the addenda received by them during the tendering period and taken into account by them in preparing their tender.

1. EXTENSION TO CLOSING DATE TO OCTOBER 4, 2022

The closing date for this Request for Quotation will be extended to:

October 4, 2022, at 2:00 pm local time.

2. CLARIFICATIONS ON SCOPE

1. Question: What type of barbed wire should be used for this project?

Answer: 12.5 gauge barbed wire shall be used on this project.

2. Question: RE: Per post sizing: what are the acceptable sizes for the posts?

Answer: The corner posts shall be 6 and 1/4"(inches) and the line posts (Main Posts) shall be 4 and 1/4"(inches).

End of Addendum A-01