

# ADDENDUM 01

Project:	Aquaplex Woman Shower Room Upgrade	Addendum:	<b>A- 01</b>
Location:	100 1 Avenue West	Date:	<b>July 9, 2020</b>

### To All Bidders:

<b>1. General</b>	
This addendum shall be read in conjunction with the specifications prepared for the Town of Drumheller Request for Quotation for Aquaplex Woman Shower Room Upgrade.	
1.1. Where inconsistent with the above, this addendum shall govern. This addendum forms an integral part of the Contract Documents and shall be included therein.	
1.2. No consideration shall be allowed for increases (extras) to the CONTRACT PRICE due to failure of the Contractor or Subcontractor not being familiar with this addendum.	
1.3. The Bidder shall insert in the Request for Quotation Form, the number(s) of the addenda received by them during the quotation period and taken into account by them in preparing their quotation.	
<b>2. Scope of the Addendum – Additional Information</b>	
	<b>ADDITIONAL INFORMATION</b>
<b>1.</b>	<b>SPECIFICATIONS:</b> <ol style="list-style-type: none"> <li>1. Remove and replace the existing Mixing valve with a new specified mixing valve.</li> <li>2. Remove old showerheads and related fixtures in existing block wall, patch block wall penetrations with an approved cement product.</li> <li>3. Install new 2"x4" Metal stud wall (16"OC) to existing block wall, fasten to floor, underside of ceiling and to block walls.</li> <li>4. Mount all plumbing fixtures to new wall as per current Plumbing Codes</li> <li>5. Wall finish to be 5/8 M.R. drywall taped, sanded and painted. Surface to be ready to accept wall tile.</li> <li>6. Relocate existing floor drain in the women shower room to approximately 6 inches from the face of new wall.</li> <li>7. Additional floor drain to be installed in Shower room hallway. Location was shown at the site visit</li> <li>8. All new concrete to be doweled into existing floor slab with ½ rebar and reinforced with wire mesh.</li> <li>9. Separate price to install a pool deck shower; complete with shower head, handle and grab bar. Location of pool deck shower was shown at site visit.</li> </ol>

**End of Addendum 01**