

NOTICE TO POTENTIAL PROPONENTS ADDENDUM 1

To all Bidders:

The following changes, additions, and/or deletions are hereby made a part of RFQ Documents as fully and completely as if the same were fully set forth therein:

Date: March 3, 2023	
em	Detail
A1.1	Clarification on Scope of Work
	To better clarify the scope of this project, please see the following:
	Question 1:
	Is the crack sealing intended to be performed as "blow and go", or rout and fill?
	Answer 1.
	A router is not required for this project.
	Per the RFQ documents Section 2.1 Scope of Work items 1 - 6:
	1. The Town of Drumheller requires the use of MACSEAL 6690-2 hot applied joint and crack sealant, ASTM 6690 TYPE 2 & 3 or equivalent.
	2. Unless otherwise directed by the Town of Drumheller, all: a. transverse cracks between 5mm and 25mm in width and b. longitudinal cracks between 5mm and 12mm in width
	which are within the pavement surface shall be: a. cleaned of debris b. air blown c. and sealed
	3. Prior to the application of crack sealant: a. the road surface adjacent to the cracks shall be cleaned b. all loose material and moisture shall be removed from all cracks
	4. All debris resulting from cleaning shall be removed from the road surface.
	5. All cracks shall be treated with compressed air lance until the pavement in the cracks is dry and slightly darkened.
	6. There shall be a maximum time period of two (2) minutes between cleaning and drying the cracks and the application of the crack sealant.